

G T Road By Pass, Jalandhar-144011, Punjab (India) EPABX-0181-2690301 & 453 website: <u>www.nitj.ac.in</u> email: <u>registrar@nitj.ac.in</u>

Ref. e-Tender Notice No. NITJ/PUR/137/22/ e-tender no. 56/2022

	Please find enclosed herewith the following:	Page No.
1.	e-Tender Notice No. NITJ/PUR/137/22/ e-tender no. 56 /2022 & Schedule for Opening of the e-Tender	2
2.	Annexure-I (Detail of Supply, Testing and Commissioning of VRF Unit , Tender Fee & EMD)	3
3.	Important Note	4
4.	Instruction to Tenderers	5-7
5.	Tender Evaluation	8-10
6.	Terms & Conditions	11-12
7.	Acceptance of terms and conditions	13
8.	Questionnaires A & B	14-15
9.	Performa for performance statement	16
10.	Annexure 'A' (Specifications of the Equipment)	17
11.	Annexure 'B' & 'C' (Format For Performance Bond/ Guarantee & Format For Performance Bond (Bank Guarantee)	18-19
12.	Annexure – 'D' (Format for Manufacturer's Authorization Form)	20
13.	Annexure- 'E' (Declaration Regarding Blacklisting/ Debarring for taking part in Tender)	21
14.	Annexure – 'F' (Certificate of Warranty)	22
15.	Annexure-'G' (Self Declaration for local content)	23
		I

Assistant Registrar Dr. B. R Ambedkar NIT Jalandhar Email: <u>arpurchase@nitj.ac.in</u>



THIS DOCUMENT IS FOR REFERENCE ONLY. ONLY E-TENDERS WILL BE ACCEPTED

e-Tender Notice No. NITJ/PUR/137/22/ e-tender no. 56 /2022

National Institute of Technology, Jalandhar invites e-tender for **Supply, Testing and commissioning of VRF Unit** required for **Setting up New Lab in IT Department** as per detail available at <u>Annexure-I</u> along with Tender Fee & EMD as per details given below:

I	Downloading & Submission of Online e-tender/bids	Start Date: 14.10.2022 at 03:00 PM
II	Last date of submission of online bids	End Date: 0 4 .11.2022 upto 03:00 PM
111	Physical submission of Tender Fee and EMD	End Date: 0 7 .11.2022 upto 03:00 PM
IV	Opening of Technical e-Bid (online)	07.11.2022 at 03:00 PM

Detailed Terms and Conditions are available in e-tender document. The bid document can be downloaded from the <u>CPP Portal</u>.

Complete tender document is available for reference purposes on Institute website <u>www.niti.ac.in</u> and <u>CPP Portal.</u> Only e-tenders will be accepted.

NOTE: This is a domestic Tender according to the DPIIT Order dated 16.09.2020 and subsequent amendments to the order for Public Procurement Preference & PROVISION FOR LOCAL SUPPLIERS TOWARDS PREFERENCE TO MAKE IN INDIA. The bidder required to provide a declaration from the Original Equipment Manufacturer (OEM) on their letter head the percentage of Local Content for the quoted instrument / item and submit with the Technical bid as per Annexure-G. Only lass-I and Class –II Local suppliers will be eligible to participate in tender. Non-Local supplier are not eligible to participate in tender. Bidder should also give details of the location(s) at which the local value addition is made in the Annexure, failing which the bid be rejected.

Registrar



Annexure-I

Ref. No. e-Tender Notice No. NITJ/PUR/137/22/ e-tender no. 56 /2022

Detail of Various Equipment, Tender Fee & EMD are as under:

Sr. no.	Item/Equipment	Qty.	Tender Fee	EMD
	Supply, Testing and commissioning of VRF Unit	01	Rs. 500/-	Rs. 47,000/-

Note: The quantity of required equipment/item may vary as per requirement. The bidder may quote for any one or all above mentioned item/equipment.

*Exemption of Tender fee & EMD will only be given to MSME/NSIC registered bidders.



Important Note

- 1. All corrigenda, addenda, amendments and clarifications regarding this tender document will be uploaded on the website <u>www.nitj.ac.in</u> and CPP Portal and not in the newspaper; Bidders shall keep themselves updated with all such developments.
- 2. In case, the last date of receipt/opening of bids falls on holiday, the bids shall be receipt/opened on the next working day at same time.
- 3. In case, the last date of submission of EMD & Tender fee falls on holiday, the EMD & Tender fee shall be submitted on the next working day at same time.
- 4. Tenderer who have downloaded the tender document form from the institute website, shall submit a declaration along with tender document that I/We have downloaded the Tender Form from the institute website <u>www.nitj.ac.in</u> and I/we have not tempered /modified the tender form in any manner. In case, if the same is found to be tempered/modified in any manner, I/we understand that my/our tender will be summarily rejected and I/we are liable to be banned from doing business with institute.
- 5. Tender fee of Rs.500/- (Non- refundable) in the form of DD in favour of <u>Director, D</u> <u>R B R Ambedkar NIT, Jalandhar.</u>
- 6. EMD (refundable) in the form of DD in favour of <u>Security- A/c, DR B R Ambedkar</u> <u>NIT, Jalandhar</u>.
- 7. <u>Both EMD and Tender fee are be submitted as per dates mentioned in schedule.</u> <u>failing which e-bids will not considered.</u>
- All the bidders are required to submit the Tender Fee and EMD as per requirement of tender document failing which bids received straightway rejected and bid will be treated invalid.
- Note: If the bidder inadvertently or otherwise upload the quoted rates in the technical bid, the bid will be straightway rejected and treated invalid.
- If the bidder is exempted for payment of Tender Fee and EMD as NSIC/MSME registered bidders, then bidder is required to submit NSIC/MSME exemption certificate for same. The Certificate must be valid as on last date of submission of bid.

Tenderer must submit a scanned copy (duly signed and stamped) regarding terms & conditions as per our tender documents along-with make/model. specifications. bill of quantity as per required equipment in the technical bid for examine the bid as per our institute tender documents. It is noted that no rate should be depicted in the letter head.



Instructions to Tenderer

- 1. No tender will be accepted in physical form. The bidders shall have to submit their bids online in Electronic Format under Digital Signatures. For participation in the e-tendering process, the bidders need to register themselves on CPP Portal.
- 2. Bids are to be submitted online and opened online as per time given failing which no tender will be considered.
- 3. Bids will be opened online as per time given schedule.
- 4. Before submission of online bids, bidders must ensure that scanned copies of all the necessary/relevant documents have been uploaded with the bid which should be duly signed and stamped. The duly signed and stamped copies of Terms & Conditions of the tender, reply of the Questionnaire of Plant & Machinery and other documents of the Tender & Annexures must be uploaded, failing which their bids may be rejected.
- 5. NIT JALANDHAR, will not be responsible for any delay in online submission of bids due to any reason whatsoever.
- 6. Bidders should also upload the scanned copies of Tender fees/EMD/Exemption Certificate as specified in the tender documents along with online technical documents. EMD in the form of a Demand Draft in favour of the <u>Security – A/c.</u> <u>Dr B R Ambedkar NIT, payable at Jalandhar</u> (refundable separate) and Tender Fee in the form of a Demand Draft in favour of the <u>Director, Dr B R Ambedkar</u> <u>NIT, payable at Jalandhar</u> (Non- refundable separate) should also be submitted in physical form to the following address as per scheduled time given for physical submission of EMD and Tender fee. The Envelope should be superscribed as EMD and Tender Fee for Tender for Supply, Testing and commissioning of VRF Unit required for Setting up New Lab in IT Department of the Institute and sent to following address:-

Kind Attention- Assistant Registrar (Purchase Section) Director, Dr B R Ambedkar National Institute of Technology, G T Road Amritsar By Pass, Jalandhar-144027, Punjab (India).

- 7. The details of EMD specified in the tender document should be same as submitted online (scanned copies). Otherwise tender will be rejected summarily.
- 8. The conditional bids shall not be considered and will be out rightly rejected.

Read and Accepted



- 9. The Financial Bid through e-tendering process shall be opened of only those bidders, who will qualify in the technical bid and approved by the Purchase Committee/Technical Experts. The date, time & place of opening of the financial bid(s) will be intimated in due course of time.
- 10. At any time prior to the deadline for submission of bid, the institute may, for any reason, whether at its own initiative or in response to a clarification requested by a prospective tenderer(s), modify the tender document by issuance of an amendment.
- 11. The amendment will be uploaded on Institute website and CPP Portal only. In order to provide reasonable time to prospective tenderer(s), for preparing their bid as per amendment, the institute may, at its discretion extend the deadline for the submission of tender.

12. The supplier must upload the original manuals / catalogue and Make/Model of the Equipment /Item. Otherwise bid is liable to be rejected.

- 13. The Institute is not liable to pay any interest on EMD. Earnest money deposit shall be forfeited, if the tenderer, withdraws its bid during the period of tender validity. The Earnest money deposit of the tenderer, whose tender has been accepted, will be returned on the submission of <u>performance security @ 3% of the total value of the offer. The performance security will be kept till the warranty period + 02 months more of the Equipment /Item. The warranty period will start from the date of satisfactory installation of the Equipment /Item duly given by the <u>concerned department.</u> Earnest money deposit of the successful tenderer shall be forfeited, if it refuses or neglects to execute the contract or fails to furnish the required performance security within the time frame as specified by the institute. The EMD(s) of other Bidder(s) whose offer are found according to required specifications/ lowest will be released after finalization of Technical Bids/ Lowest Bid/Purchase.</u>
- 14. The Format of Performance Bank Guarantee bond or Performance Bank Guarantee issued by the bank as per the format given in <u>Annexure "B" & "C"</u>.
- 15. Delivery time is the essence of the contract and must be met with.
- 16. Nearest specifications/better specifications can be considered. In case of deviation, complete justification should be furnished with proper documents.
- 17. The Director may accept a tender in part or whole of the quantity offered, reject any tender without assigning any reasons and may not accept the lowest bidder. Further in case of any doubt/dispute, the decision of the Director of the Institute shall be final.
- 18. The offer shall be kept valid for minimum 120 days.

Read and Accepted.



- 9. a) Either the agent/ dealer on behalf of the Principal/OEM or Principal/OEM itself can bid but both cannot bid simultaneously for the same item/product in the same tender.
 - b) If an agent/ dealer submits bid on behalf of the Principal/OEM, the same agent /dealer shall not submit a bid on behalf of another Principal/OEM in the same tender for the same item/product.
 - c) Only one agent/dealer of single Principle/OEM can submit the bid. If more than one agent/dealer of same OEM/Principal quote in the tender, then bids of all the bidders of single OEM/Principle are liable to be rejected.
 - d) All offers other than those from the Principal/OEM should be supported by an authority letter from the manufacturer authorizing the dealer /supplier to tender on their behalf as per <u>Annexure-D</u>. In case of manufacturer, a certificate or a copy thereof to the effect that the bidder is a manufacturer of the Equipment /Item must be accompanied with the technical bid.
- 20. The supplier will be responsible till the entire stores contracted for, arrive in good condition at destination.
- 21. The tenderer should not have been debarred and/ or blacklisted by any Central Government/ or any State Government Department(s). This must be supported by an affidavit as per format given in **Annexure-"E"**.
- 22. If any information furnished by the bidder is, at any stage found to be incorrect/false/fabricated, the Institute shall have the absolute right to forfeit the EMD, warranty/performance guarantees or/and security deposits, in addition to cancellation of contract, and in accordance with law, such other actions may be taken like black-listing of the bidder etc.

Read and Accepted.



TENDER EVALUATION

Institute will evaluate all the proposals to determine whether these are complete in all respects as specified in the tender document. Evaluation of the proposals shall be done in two stages as:

(a) <u>Stage – I (Technical Evaluation):</u>

(i) Institute shall evaluate the technical bid(s) to determine the following like the bid qualifies the essential eligibility criteria or not , the tenderer has submitted the EMD & Tender fee or not, any computational errors have been made or not, all the documents have been properly filled or otherwise, all the documents have been submitted/ uploaded with technical bid or not, the specifications, Make/Model, Catalogue of quoted Equipment /Item are as per requirement tender specifications or not, Authorization of Dealer / Distributor/ Exclusive Agent certificate from manufacturer is in order or not, Sales & service policy of equipment / item during warranty period and after warranty period will also be seen, location of their authorized service center will also be seen for evaluation etc.

After evaluation of technical bid(s), a list of the qualifying tenderer (s)/ bidder s) shall be made. Short-listed tenderer(s) will be informed of the date, time and place of opening of financial bid(s) and they may attend or depute their authorized representative/s to attend the schedule of opening of financial bid(s) on the scheduled date and time, if they wish to do so. The representative(s) should have a letter of authority to attend the price bid(s) opening event.

Read and Accepted



PART – II (e-FINANCIAL BID):

- a) Bidders should offer the rates as per the format of BOQ as available on CPP Portal. Detailed bill of material/quantity is also to be provided along with the price breakup of each item as per requirement of the tendered specification of the equipment in the online price bid at <u>CPP Portal</u>.
- Note: The quoted amount as filled in the Annexure(s) of online financial bid and detailed bill of material/quantity provided with price break up of each item in the online financial bid should be tallied and both must be same. otherwise bid will be treated invalid.

Read and Accepted.



ARBITRATION:

In case of any dispute or difference arising out in connection with the tender conditions/job order/Contract, the Institute and the Seller/Service Provider will address the dispute/difference for a mutual resolution and failing which, the matter shall be referred for arbitration to a sole Arbitrator to be appointed by the Institute.

The Arbitration shall be held in accordance with the provisions of the Arbitration and Conciliation Act, 1996 and the venue of arbitration shall be at Jalandhar only. The decision of the Arbitrator shall be final and binding on both the parties.

JURISDICTION:

The courts at Jalandhar alone will have the jurisdiction to trial any matter, dispute or reference between parties arising out of this tender / contract. It is specifically agreed that no court outside and other than Jalandhar Court shall have jurisdiction in the matter.

Read and Accepted.



(TERMS AND CONDITIONS (FOR THE SUPPLY OF GOODS, EQUIPMENT /ITEM)

1. Rate should be quoted F.O.R NIT Jalandhar and In INR only.

2. Where the Equipment / Machinery/ Instrument are composed of several sub units/components, the rate should be quoted for each subunit/component separately. NIT Jalandhar reserves the right to increase or decrease the number of sub units/components and number of Equipment / Machinery/ Instrument according to its requirements.

3. The institute being government educational institute is having Excise and Custom duty exemption in terms of government notification No. 51/96-customs Dt. 23-7-1996 and No. 10/97-central excise Dt. 1-3- 1997 as amended from time to time, therefore taxes be quoted accordingly and this must be depicted in Price Bid clearly.

4. GST or any other chargeable duty where applicable must be specifically mentioned, failing which no tax or duty will be allowed at subsequent stage.

5. All items shall be indicated both in words as well as in figures. If there is difference between amount quoted in words and figures, amount quoted in words shall prevail.

6. Payment:

(a) 100% payment will be made against physical delivery, inspection, installation, training of the Equipment/Machinery/Instrument etc. in the institute, receipt of satisfactory working report of the Equipment / Machinery/Instrument etc. and receipt of Performance Bank Guarantee @ 3%.

7. Warranty: Rates should be quoted with comprehensive warranty. Besides this, policy regarding after sale service on the expiry of warranty period of Equipment / Machinery/Instrument etc. may be explained. The bidders should attach duly signed and stamped certificate of warranty as per <u>Annexure-F</u> with the technical bid.

8. Training: In house training (where applicable) after the installation and commissioning of Equipment / Machinery/Instrument etc. shall be provided by the supplier.

9. **Delivery:** Delivery date will be mentioned in the supply order. The time and date of delivery or dispatch stipulated in a supply order shall be deemed to be the essence of the supply order and if the supplier fails to deliver or dispatch any consignment within the period prescribed for such delivery, the delayed consignment will be accepted subject to penalty as laid down in the supply order, which will be recovered from the pending payments.

Read and Accepted.



1. No recovery of penalty will be made, if the delayed supplies are acceptable by extending the delivery period by the Director with our any LD charges.

2. Director will allow extension on the request of the supplier by recording in writing that in exceptional circumstances the supply was beyond the control of the supplier and there was no loss to the institute.

3. Penalty on account of delay, Director NIT, Jalandhar reserves the right to impose 0.5% (Half) per cent penalty per week on account of delay in supply, if delivery received after expiry of the original delivery period. The total penalty will not exceed 10% of the value of the delayed goods.

10. Installation: Supplier has to install the Equipment / Machinery/ Instrument within two to three weeks from the receipt of the Equipment / Machinery/Instrument etc. in NIT Jalandhar.

11. Spares and Accessories, wherever required should be quoted separately and clearly, even if these are not asked for.

12. Site Preparation: The supplier shall inform NIT Jalandhar about the site preparation, if any, needed for the installation, immediately after receipt of the supply order. Supplier must provide complete details regarding space and all infrastructural requirements needed for the Equipment / Machinery/Instrument etc which NIT Jalandhar should arrange before the arrival of Equipment / Machinery/Instrument etc to ensure its early installation and smooth operation thereafter. The supplier may offer his advice and render assistance to NIT Jalandhar in the preparation of the site and other pre installation requirements.

13. The total scope of work includes the supply, installation, satisfactory commissioning and testing of the Equipment / Machinery/Instrument etc by the supplier, training at NIT Jalandhar, method development and validation for parameters as mentioned in specifications at <u>Annexure-A</u>. The supplier will complete installation & Commissioning of Machine within two to three weeks from the date of receipt of Equipment / Machinery/Instrument etc. of NITJ.

14. Details about the service center for the quoted Equipment / Machinery/Instrument etc. in India may be mentioned.

Read and Accepted.



Acceptance

We	_read and accept the instructions to the
tenderer, terms & conditions and all and shall comply with them strictly.	other documents as mentioned in the tender
Name of Bidder	
	Signature

Address _____

Seal of firm:

Date:



G T Road By Pass, Jalandhar-144011, Punjab (India) EPABX-0181-2690301 & 453 website: <u>www.nitj.ac.in</u> email: <u>registrar@nitj.ac.in</u>

Questionnaires A & B

QUESTIONNAIRE FOR PLANT & MACHINARY

Note: Please submit the reply in detail and also enclose the necessary documents with proof where required as per Questionnaire. These documents must be submitted in the technical bid document.

Please state that you have submitted your quotations as per procedure mentioned below:-

- Bids consisting of technical details bringing out clearly in a separate sheet ,the deviation in the specifications if any from that of tender enquiry specifications along with commercial terms and tender form.
- 1. Please attach list dully signed by you, for such spare parts and tools which are absolutely essential for proper maintenance and operation of machine for a period of two years giving full particulars of spare and tool with a price of each spare parts and tools separately.
- 2. Please confirm that you have adequate servicing and spare parts facilities in India in respect of Equipment /Item tendered by you or that you should arrange to provide such facilities simultaneously.
- 3. Please indicate that you guaranteed that before going out of production of spare parts, you will give adequate advance notice to the purchaser so that the institute may order his requirements of spares in one lot, if he so desire.
- 4. Please indicate that you guaranteed that if you go out of production of spare parts, then you will make available prints, drawings of the spare parts and specifications of the material at no cost if and when required in connection with Equipment /Item to enable the purchaser to fabricate or procure spare parts from other sources.
- 5. Please confirm that you undertake to enter into a rate contact with the purchaser to supply spare parts on an agreed basis for an agreed period.
- 6. Status:
 - a) Indicate whether you are ISU or SSI
 - b) Are you registered with Government e-Marketing (GeM) for the item quoted? If so indicate whether there is any monetary limit or registration.
 - c) If you are a small scale unit registered with NSIC under single point registration scheme whether there is monetary limit.
- 7. a) If you are registered either with NSIC or with Government e-Marketing (GeM), please State whether you are registered with Directorate of industries of the state government concerned.

b) If so, confirm whether you have attached a copy of the certificate, issued by Director of industries.

- 8. Please indicate:-Name & Full Address of your Banker
- 9. Please indicate whether you agree to submit advance samples if called upon to do so within the specified period of 21 days.



- 10. Business name and constitution of firm:
 - i)The Indian company Act.1956
 - ii)Indian partnership Act.1932
 - iii)Any act, if not, who are the owner/partners (please give full name and address)
- 11. Whether the tendering firm is / are:
 - i) Manufacturers authorized agents
 - ii) Holders stock of the stores tendered for
 - iii) NBI manufacturer's agents please enclose with tender the copy of manufacturer's authorization.
- 12. Please state whether the inspection clause is acceptable to you
- 13. Here state specifically:
 - i) Whether the price quoted by you is to the best of your knowledge and belief is not more than the price usually charged by you on stores of the same natures, class of description to any private purchase either foreign or as well as government purchaser. If not state the reason thereof if any also indicates the margin of Difference.
 - ii) In respect of indigenous items for which there is a controlled price fixed by law, the price quoted shall not be higher than that the controlled price and rates available on DGS&D/ Government e-Marketing (GeM) contract. The reason thereof should be stated.
- 14. State whether business dealing with you has been banned by Ministry /Department of supply or any other Govt. Department.
- 15. Please confirm that you have read all the instruction carefully and have complied with accordingly.

(Signature of Tenderer)

1. Full Name & Address of the person signing

Whether signing as proprietor /partners



Dr B R AMBEDKAR NATIONAL INSTITUTE OF TECHNOLOGY G T Road By Pass, Jalandhar-144011, Punjab (India) EPABX-0181-2690301 & 453 website: www.nitj.ac.in email: registrar@nitj.ac.in

PERFORMA FOR PERFORMANCE STATEMENT

(For the Period of last 3 years)

e-T	e-Tender Notice No. NITJ/PUR/137/22/ e-tender no. 56/2022							
Sr. No.	Order (full	Order No. &	Description	Value of		Has the		
	placed	dated	And	Order	Completion	Equipment/Item		
	address of		Qty. of Stores		of delivery	been		
	purchaser)		Ordered			satisfactory		
						commissioned		
I				1		<u> </u>		



Dr B R AMBEDKAR NATIONAL INSTITUTE OF TECHNOLOGY EPABX-0181-2690301 & 453 website: www.nitj.ac.in email: registrar@nitj.ac.in

Annexure "A"(I)

55555256540525%4F9F50	Ariable Refrigerant Volume System supplying, installation, testing and commissioning of Air Cooled VRV/VRF units with scroll Compressor capable of modulating capacity e. it should be able to vary speed of the compressor as per the varying load conditions and works on R410A with heating & coming oth. The outdoor unit shall be a factory assembled unit housed in a sturdy weather proof casing constructed from rust-proofed mild teel panels coated with powder coated finish. The outdoor unit shall have scroll compressors and be able to operate even in case of breakdown of one of compressor Each unit shall be equipped, with an oil separator to ensure stable operation with long engerant piping etc. Condenser Shall have with Hydrophilic Coating and Corrosion Resistance Black Coated Fini All compressor shall ave inverter technology i.e. outdoor units shall have all inverter based compressor. The manufacturer of ODU and compressor shall is earlie, i.e. the make of compressor shall be identical of the ODU. All Bidders has to submit the test certificates along with the lelivery of VRF/VRV Units at site. A draft Format of the same need to be submitted along with in the Technical Bid. All compressor hall have inverter technology i.e. outdoor units shall have all inverter based compressor. (Chinese Manufacturing Machinery is not isceptable). The rates is inclusive all types taxes as imposed by the Government. Dutdoor Unit supplying, Installation Testing and Commissioning Including vacumising. Gas charging of Modular type outdoor units equipped with ingibly efficient scroll compressors, with all Inverter Scroll type compressor(s), special acryl pre-coated heat exchanger, low noise indenser fan, auto check function for connection error etc, centralized controller for individual control complete as per OEM pecifications of Following Capacity. Will compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor the manufacturer of ODU and compressor shall be same. i.e. the mak		
55555256540525%4F9F50	Aupplying, installation, testing and commissioning of Air Cooled VRV/VRF units with scroll Compressor capable or mobulating acpacity e. it should be able to vary speed of the compressor as per the varying load conditions and works on R410A with heating & cooling work. The outdoor unit shall be a factory assembled unit housed in a sturdy weather proof casing constructed from rust proofed mild teel panels coated with powder coated finish. The outdoor unit shall have scroll compressors and be able to operate even in case of breakdown of one of compressor. Each unit shall be equipped, with an oil separator to ensure stable operation with long engerant piping etc. Condenser Shall have with Hydrophilic Coating and Corrosion Resistance Black Coated Fin. All compressor shall ave inverter technology i.e. outdoor units shall have all inverter based compressor. The manufacturer of ODU and compressor shall ave inverter technology i.e. outdoor units shall be identical of the ODU. All Bidders has to submit the test certificates along with the elivery of VRF/VRV Units at site. A draft Format of the same need to be submitted along with in the Technical Bid. All compressor hall have inverter technology i.e. outdoor units shall have all inverter based compressor. (Chinese Manufacturing Machinery is not isceptable). The rates is inclusive all types taxes as imposed by the Government. Dutdoor Unit Installation Testing and Commissioning Including vacumising, Gas charging of Modular type outdoor units equipped with isply efficient scroll compressors, with all Inverter Scroll type compressor(s), special acryl pre-coated heat exchanger, low noise isplicitions of Following Capacity. Ill compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor shall have inverter of ODU and compressor shall be same i.e. the make of compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
55555256540525%4F9F50	Aupplying, installation, testing and commissioning of Air Cooled VRV/VRF units with scroll Compressor capable or mobulating acpacity e. it should be able to vary speed of the compressor as per the varying load conditions and works on R410A with heating & cooling work. The outdoor unit shall be a factory assembled unit housed in a sturdy weather proof casing constructed from rust proofed mild teel panels coated with powder coated finish. The outdoor unit shall have scroll compressors and be able to operate even in case of breakdown of one of compressor. Each unit shall be equipped, with an oil separator to ensure stable operation with long engerant piping etc. Condenser Shall have with Hydrophilic Coating and Corrosion Resistance Black Coated Fin. All compressor shall ave inverter technology i.e. outdoor units shall have all inverter based compressor. The manufacturer of ODU and compressor shall ave inverter technology i.e. outdoor units shall be identical of the ODU. All Bidders has to submit the test certificates along with the elivery of VRF/VRV Units at site. A draft Format of the same need to be submitted along with in the Technical Bid. All compressor hall have inverter technology i.e. outdoor units shall have all inverter based compressor. (Chinese Manufacturing Machinery is not isceptable). The rates is inclusive all types taxes as imposed by the Government. Dutdoor Unit Installation Testing and Commissioning Including vacumising, Gas charging of Modular type outdoor units equipped with isply efficient scroll compressors, with all Inverter Scroll type compressor(s), special acryl pre-coated heat exchanger, low noise isplicitions of Following Capacity. Ill compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor shall have inverter of ODU and compressor shall be same i.e. the make of compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
2 2 # 5 2 2 5 5 5 4 0 % 2 2 % 4 F 2 F 2 O	e. It should be able to vary speed of the compressor as per the varying load conditions and works on R4104 with Healing a costing onth. The outdoor unit shall be a factory assembled unit housed in a sturdy weather proof casing constructed from rust-proofed mild teel panels coated with powder coated finish. The outdoor unit shall have scroll compressors and be able to operate leven in case of breakdown of one of compressor. Each unit shall be equipped, with an oil separator to ensure stable operation with long efficient piping etc. Condenser Shall have with Hydrophilic Coating and Corrosion Resistance Black Coated Fin. All compressor shall ave inverter technology i.e. outdoor units shall have all inverter based compressor. The manufacturer of ODU and compressor shall be identical of the ODU. All Bidders has to submit the test certificates along with the elliptery of VRF/VRV Units at site. A draft Format of the same need to be submitted along with in the Technical Bid. All compressor hall have all inverter based compressor. (Chinese Manufacturing Machinery is not inceptable). The rates is inclusive all types taxes as imposed by the Government. Dutdoor Unit Dutdoor Unit Inverter Scroll type compressor(s), special acryl pre-coated heat exchanger, low noise indepted on the ord or units shall have all inverter based controller for individual control complete as per OEM indepted for non-solid pre-coated heat exchanger, low noise indepted for soft for connection error etc, centralized controller for individual control complete as per OEM perifications of Following Capacity. Ill Compressor shall have in every end compressor shall be same. i.e. the make of compressor shall be same in the make of compressor shall be adders has been units and the solution of the ODU. All Bidders has on solution and the perifications of Following Capacity.		
2 8 5 2 2 2 5 5 4 0 5 2 2 3 4 F 2 F 2 F 0	In the outdoor unit shall be a factory assembled unit housed in a study weather proof casing totals outdoor units be over in case the panels coated with powder coated finish. The outdoor unit shall have scroll compressors and be able to operation with long of the panels coated with powder coated finish. The outdoor unit shall have scroll compressors and be able to operation with long of the panels coated with powder coated finish. The outdoor unit shall have scroll compressors and be able to operation with long of the panels coated with an originate leven in case of the panels coated with provide leven in case of the panels coated with the provide leven in case of the panels coated with an originate leven in the test certificates along with the panel inverter technology i.e. outdoor units shall have all inverter based compressor. The manufacturer of ODU and compressor shall be earner it.e. the make of compressor shall be identical of the ODU. All Bidders has to submit the test certificates along with the test certificates along with the earlier of VRF/VRV Units at site. A draft Format of the same need to be submitted along with in the Technical Bid. All compressor hall have all inverter based compressor. (Chinese Manufacturing Machinery is not inceptable). The rates is inclusive all types taxes as imposed by the Government. Dutdoor Unit Dutdoor Unit Dutdoor Unit and Commissioning Including vacumising. Gas charging of Modular type outdoor units equipped with alighty efficient scroll compressors, with all Inverter Scroll type compressor(s), special acry) pre-coated heat exchanger, low noise ingitity efficient scroll compressors, with all Inverter Scroll type compressor shall be identical of the ODU. All Bidders has or individual control complete as per OEM pecifications of Following Capacity. No compressor shall have all inverter based compressor shall be identical of the ODU. All Bidders has or individual control complete as per OEM pecifications of Following Capacity. No compressor shall have all inverte		
STEELED SECONE UNAF SEEO	Leef panels coated with powder coated finish. The outdoor unit shall have scholl compressors and be able to "provide the provide the pr		
5 2 2 3 8 5 4 0 6 2 8 8 4 F 8 F 8 O	If breakdown of one of compressor Each unit shall be equipped, with an oil separator to ensure shall compressor shall engineering and corrosion Resistance Black Coated Fin All compressor shall have with Hydrophilic Coating and Corrosion Resistance Black Coated Fin All compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor. The manufacturer of ODU and compressor shall be identical of the ODU. All Bidders has to submit the test certificates along with the test certificates along with the inverter technology i.e. outdoor units shall have all inverter based compressor. (Chinese Manufacturing Machinery is not hall have inverter technology i.e. outdoor units shall have all inverter based compressor. (Chinese Manufacturing Machinery is not hall have inverter technology i.e. outdoor units shall have all inverter based compressor. (Chinese Manufacturing Machinery is not loceptable). The rates is inclusive all types taxes as imposed by the Government. Dutdoor Unit inpolving, Installation Testing and Commissioning Including vacumising, Gas charging of Modular type outdoor units equipped with highly efficient scroll compressors, with all Inverter Scroll type compressor(s), special acryl pre-coated heat exchanger, low noise indenser fan, auto check function for connection error etc, centralized controller for individual control complete as per OEM perifications of Following Capacity . Ill compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
2 2 3 5 5 4 0 5 2 3 3 4 F 2 F 2 O	engerant piping etc. Condenser Shall have with Hydrophilic Coating and Corrosion Resistance Back Coated muta- have inverter technology i.e. outdoor units shall have all inverter based compressor. The manufacturer of ODU and compressor shall be ame, i.e. the make of compressor shall be identical of the ODU. All Bidders has to submit the test certificates along with the lelivery of VRF/VRV Units at site. A draft Format of the same need to be submitted along with in the Technical Bid. All compressor hall have inverter technology i.e. outdoor units shall have all inverter based compressor. (Chinese Manufacturing Machinery is not liceptable). The rates is inclusive all types taxes as imposed by the Government. Dutdoor Unit hupplying, Installation Testing and Commissioning Including vacumising. Gas charging of Modular type outdoor units equipped with hupplying. Installation Testing and Commissioning Including vacumising. Gas charging of Modular type outdoor units equipped with hupplying. Installation Testing and Commissioning Including vacumising. Gas charging of Modular type outdoor units equipped with hupplying. Installation Testing and Commissioning Including vacumising. Gas charging of Modular type outdoor units equipped with hupplying. Installation Testing and Commissioning Including vacumising. Gas charging of Modular type outdoor units equipped with hupply difficient scroll compressors, with all Inverter Scroll type compressor(s), special acryl pre-coated heat exchanger, low noise igned fictures of Following Capacity . Ill compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor he manufacturer of ODU and compressor shall be same i.e. the make of compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
	ave inverter technology i.e. outdoor units shall have all inverter based compressor. The maintaintiation of users along with the exame, i.e. the make of compressor shall be identical of the ODU. All Bidders has to submit the test certificates along with the elivery of VRF/VRV Units at site. A draft Format of the same need to be submitted along with in the Technical Bid. All compressor hall have inverter technology i.e. outdoor units shall have all inverter based compressor. (Chinese Manufacturing Machinery is not inceptable). The rates is inclusive all types taxes as imposed by the Government. Dutdoor Unit implying, Installation Testing and Commissioning Including vacumising, Gas charging of Modular type outdoor units equipped with implying findent scroll compressors, with all Inverter Scroll type compressor(s), special acry) pre-coated heat exchanger, low noise iondenser fan, auto check function for connection error etc, centralized controller for individual control complete as per OEM pecifications of Following Capacity. Ill compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor the manufacturer of ODU and compressor shall be same. i.e. the make of compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
	Same, Lé, the make of compressor shall be identical of the ODU. All Bidders has to south the technical Bid All compressor televery of VRF/VRV Units at site. A draft Format of the same need to be submitted along with in the Technical Bid. All compressor hall have inverter technology i.e. outdoor units shall have all inverter based compressor. (Chinese Manufacturing Machinery is not icceptable). The rates is inclusive all types taxes as imposed by the Government. Dutdoor Unit upplying, Installation Testing and Commissioning Including vacumising, Gas charging of Modular type outdoor units equipped with inghly efficient scroll compressors, with all Inverter Scroll type compressor(S), special acryl pre-coated heat exchanger, low noise indenser fan, auto check function for connection error etc, centralized controller for individual control complete as per OEM indenser fan, auto check function for connection error etc, centralized controller for individual control complete as per OEM indenser following Capacity . WI compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor the manufacturer of ODU and compressor shall be same. i.e. the make of compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
8 5 4 0 5 2 8 8 4 F 2 F E 0	Interference of VRF/VRV Units at site. A draft Format of the same need to be submitted along which the defaulting Machinery is not inall have inverter technology i.e. outdoor units shall have all inverter based compressor. (Chinese Manufacturing Machinery is not icceptable). The rates is inclusive all types taxes as imposed by the Government. Jubdoor Unit Supplying, Installation Testing and Commissioning Including vacumising, Gas charging of Modular type outdoor units equipped with inghly efficient scroll compressors, with all Inverter Scroll type compressor(s), special acryl pre-coated heat exchanger, low noise iondenser fan, auto check function for connection error etc, centralized controller for individual control complete as per OEM perafications of Following Capacity. Il compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor fhe manufacturer of ODU and compressor shall be same. i.e. the make of compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
8 5 4 0 5 2 8 8 4 F 2 F E 0	Interference of VRF/VRV Units at site. A draft Format of the same need to be submitted along which the defaulting Machinery is not inall have inverter technology i.e. outdoor units shall have all inverter based compressor. (Chinese Manufacturing Machinery is not icceptable). The rates is inclusive all types taxes as imposed by the Government. Jubdoor Unit Supplying, Installation Testing and Commissioning Including vacumising, Gas charging of Modular type outdoor units equipped with inghly efficient scroll compressors, with all Inverter Scroll type compressor(s), special acryl pre-coated heat exchanger, low noise iondenser fan, auto check function for connection error etc, centralized controller for individual control complete as per OEM perafications of Following Capacity. Il compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor fhe manufacturer of ODU and compressor shall be same. i.e. the make of compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
	hall have inverter technology i.e. outdoor units shall have all inverter based compressor. (Onlice the new second		
	Inceptable). The rates is inclusive all types taxes as imposed by the Government Dutdoor Unit Supplying, Installation Testing and Commissioning Including vacumising. Gas charging of Modular type outdoor units equipped with inginity efficient scroll compressors, with all Inverter Scroll type compressor(s), special acryl pre-coated heat exchanger, low noise indenser fan, auto check function for connection error etc, centralized controller for individual control complete as per OEM pecifications of Following Capacity . III compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor the manufacturer of ODU and compressor shall be same i.e. the make of compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
	Dutdoor Unit supplying, Installation Testing and Commissioning Including vacumising, Gas charging of Modular type outdoor units equipped with sightly efficient scroll compressors, with all Inverter Scroll type compressor(s), special acryl pre-coated heat exchanger, low noise indenser fan, auto check function for connection error etc, centralized controller for individual control complete as per OEM pecifications of Following Capacity. Ill compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor the manufacturer of ODU and compressor shall be same. i.e. the make of compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
	Aupplying, Installation Testing and Commissioning Including vacumising, Gas charging of Modular type outdoor units equipped when highly efficient scroll compressors, with all Inverter Scroll type compressor(s), special acryl pre-coated heat exchanger, low noise bindenser fan, auto check function for connection error etc, centralized controller for individual control complete as per OEM getifications of Following Capacity. Il compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor the manufacturer of ODU and compressor shall be same. i.e. the make of compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
	Wightly etholent scroll compressors, with all inverter scroll type (ompressor(s)), good and other compressors, with all inverter scroll type (ompressor(s)), good and other compressors are open inverter to an error etc. centralized controller for individual control complete as per OEM goodfications of Following Capacity. Will compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor. Will compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor. The manufacturer of ODU and compressor shall be same. i.e. the make of compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
	Wightly etholent scroll compressors, with all inverter scroll type (ompressor(s)), good and other compressors, with all inverter scroll type (ompressor(s)), good and other compressors are open inverter to an error etc. centralized controller for individual control complete as per OEM goodfications of Following Capacity. Will compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor. Will compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor. The manufacturer of ODU and compressor shall be same. i.e. the make of compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
	Ondenser fan, auto check function for connection error etc. Centralized Composer for escaped and the perifications of Following Capacity. Ill compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor The manufacturer of ODU and compressor shall be same. i.e. the make of compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
STATE OF MO	pecifications of Following Capacity. III compressor shall have inverter technology i.e. outdoor units shall have all inverter based compressor the manufacturer of ODU and compressor shall be same. i.e. the make of compressor shall be identical of the ODU. All Bidders has o submit the test certificates along with the delivery of VRF/VRV Units at site.		
T ST MO	The manufacturer of ODU and compressor shall be same. Let the make or compressor shall be obtained or o submit the test certificates along with the delivery of VRF/VRV Units at site.		
T ST MO	The manufacturer of ODU and compressor shall be same. Let the make or compressor shall be obtained or o submit the test certificates along with the delivery of VRF/VRV Units at site.	- 1	
E T M O	o submit the test certificates along with the delivery of VRF/VRV Units at site		
T M O	a suprim use test defondates anning mor une denter / or finite sector		
M O			
0	ALL DE LA CELLA TABLES	-	
	Nake- Daikin, LG , Mitsubishi, O General, Toshiba 2 Ut Door Unit - 22 HP Top Discharge (Cooling Cap 53000 Kcal /Hr,210,200 BTU/Hr , Heating Cap 61.6 KW) 2		Nos
s	Dut Door Unit - 22 HP Top Discharge (Cooling Cap-53000 Kcal /Hr, 210,200 BTU/Hr, Heating Cap Of Stress)		
s			
2	Supply of Indoor Units:		
	Supply of Indoor Units: Supplying, installation, testing and commissioning of below mentioned capacity Cassette indicor unit of air conditioners complete with		
p	supplying, installation, testing and commissioning or below memory of drawings	-	-
f a	an and fan motor, controls, drain Pump etc. as per specifications and drawings 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8 8		Nos.
4	an and fan motor, controls, drain Pump etc. as per specifications and drawings 4 Way Cassette Unit - 4.5 TR-) Cooling Cap-13,600 Kcal/hr ,Sound Level 44-51 dBA, Heating Cap-15,500 Kcal/Hr) B		
			Nos
e	Supplying of Imported fittings (Ref Net) Y joints etc. as per specifications as required complete in all respects of the bidding document and 8		-
P	Supplying of Imported fittings (ker Net) Y joints etc. as per specification mentioned in the bidding document and a Supplying of Cordless Remote read. to operate the indoor hi wall units as per specification mentioned in the bidding document and a		Nos
5	Supplying of Cordless Remote read, to operate the indoor hi wall units as per specification menufuled in the oldary of		
5	s per standard guidelines etc. as required 1		Nos
	Supply of Centralized Controller with Touch Screen		
D		10.100	det.
		INI	TQty.
No. F	PARTICULARS	_	+
COLUMN TO A			
	to with MS Stand		
	Installation, testing and commissioning of Air-cooled type air conditioning VRVoutdoor condensing units with MS Stand,		1
1	Installation, testing and commissioning of Altropic Articles App		LS
C	Gas Charging, Vaccumisation and Pressure testing	-	1.5
C	Out Door Unit - 44 HP Top Discharge		
I	Installation , testing and commissioning of iridoor units as per BOQ	8	NUS
-	4 Way Cassette Type Unit - 4.5 TR		
	4 Way Casselle Type Onice To the		-
	Supplying, installation, testing and commissioning of following sizes of refrigerant copper piping work with 19/13mm thick		
S	Supplying, installation, testing and commissioning or following sizes of redorr and putdoor units as per specifications duly		
	Supplying, installation, testing and commissioning of following sizes of refrigerant copper piping visits as per specifications duly closed cell elastomenc nitrile rubber tubular insulation between each set of indoor and outdoor units as per specifications duly closed cell elastomenc nitrile rubber tubular insulation between each set of indoor and outdoor units as per specifications duly closed cell elastomenc nitrile rubber tubular insulation between each set of indoor and outdoor units as per specifications duly closed cell elastomenc nitrile rubber tubular insulation between each set of indoor and outdoor units as per specifications duly closed cell elastomenc nitrile rubber tubular insulation between each set of indoor and outdoor units as per specifications duly closed cell elastomenc nitrile rubber tubular insulation between each set of indoor and outdoor units as per specifications duly closed cell elastomenc nitrile rubber tubular insulation between each set of indoor and outdoor units as per specifications duly closed cell elastomenc nitrile rubber tubular insulation between each set of indoor and outdoor units as per specifications duly closed cell elastomenc nitrile rubber tubular insulation between each set of indoor and outdoor units as per specifications duly closed cell elastomenc nitrile rubber tubular insulation between each set of indoor and outdoor units as per specifications duly closed cell elastomenc nitrile rubber tubular insulation between each set of indoor and outdoor units as per specifications duly closed cell elastomenc nitrile rubber tubular insulation between each set of indoor and outdoor units as per specifications duly closed cell elastomenc nitrile rubber tubular insulation between each set of indoor and tubular insulations duly closed cell elastomenc elasto		
C	closed cell elastomenc nitrile rubber tubular insulation between each set of indoor and butdoor and bu		
P	supported with MS hangers and clamps.	30	Mar
P P	supported with MS hangers and bamps.	20	
4	41.3mm outer dia (insulation 19mm)	5	1111
7	34.9mm outer dia (insulation 13mm)	5	PALI
	28.6mm outer dia (insulation 13mm)	90	7-111
2	20.0mm out of the end to a mm)	5	1-1tr
2	22.2mm outer dia (insulation 13mm)	E	-
1	19 1mm outer dia (insulation 19mm)	Þ	Mu
1	15.9mm outer dia (insulation 13mm)	150	Mtr
	12.7mm outer dia (insulation 13mm)	6	9-111
1	IZ./min outer and (initiation 12mm)	1	Intr
5	9.5mm outer dia (insulation 13mm)	-	- Patt
	c time a tot dia (insulation 13mm)		
f	6.4mm outer the disclusion for the second sizes including horizontal and vertical bends, cross member with suitable storger Supply and installation of GI tray of following sizes including horizontal and vertical bends, cross member with suitable size invertedly fixed and supports complete as required. The cable tray shall be covered with another GI cable tray of appropriate size invertedly fixed and supports complete as required.	Ê.	
		1	
10	and supports complete as required. The cose of plate as required, on the existing cable tray for protection etc. complete as required.	-	1.0
k	on the existing cable bay for protection end	P	MI
	s Some (wide) x Some(depth) x 1.6mm (thick)	ß	ML
	150mm (wide) × 50mm(depth) × 1.6mm (thick) 300mm (wide) × 50mm(depth) × 1.6mm (thick) Supplying, installation, testing and commissioning of following sizes of rigid PVC piping complete with elbow T-joint, socket duly Supplying, installation, testing and commissioning of following sizes of rigid PVC piping complete with elbow T-joint, socket duly		
P	Bournin (wide) a solution testing and commissioning of following sizes of rigid PVC piping complete with erbow rejoint, socket dury		
1	Supplying, installation, testing and consisted with 6mm thick closed cell nitrile rubber insulation.	+	-
5	Supplying, installation, testing and commissioning of following sizes of rigid PVCpping complexity supported as per specifications and insulated with 6mm thick closed cell nitrile rubber insulation.	60	
		5	MIL
1	25 mm	1	-
-	32 mm 32 mm Supply, Installation, Testing and Commissioning of control cum transmission wiring of 2 corex1.25 sq mm copper wire in Supply, Installation, Testing and Commissioning of control cum transmission wiring of 2 corex1.25 sq mm copper wire in Supply, Installation, Testing and Commissioning of control cum transmission wiring of 2 corex1.25 sq mm copper wire in	10	0 Mt
W	Supply, Installation, Testing and Commissioning of Control control remote controllers & for connections between indoor unit to	10	U prit
E	32 mm Supply, Installation, Testing and Commissioning of control cum transmission wining of 2 corex1.25 sq trait copper function Supply, Installation, Testing and Commissioning of control cum transmission wining of 2 corex1.25 sq trait copper function suitable PVC conduits between indoor & outdoor units to central remote controllers & for connections between indoor unit to suitable PVC conduits between indoor & outdoor units to central remote controllers & for connections between indoor unit to		
P	Buildone rive contracted and		
×	putdoor unit	b	No
	the use of the second limits	f.	Lo
1	SITC of MS Stand for VRF Outdoor Units	р	10
	STC of Ref. Gas Charging of R410a		
F	Darle of meril one of the second se		
	6		



G T Road By Pass, Jalandhar-144011, Punjab (India) EPABX-0181-2690301 & 453 website: <u>www.nitj.ac.in</u> email: <u>registrar@nitj.ac.in</u>

Annexure: "B"

FORMAT FOR PERFORMANCE BOND/GUARANTEE

(Undertaking from the supplier on a Non Judicial Stamp Paper of requisite duly attested by Notary) In consideration for "The Registrar, National Institute of Technology Jalandhar (hereinafter called NIT Jalandhar)having agreed to release the payment of net value as per terms and conditions of a concluded Order No._______dated_____(hereinafter called 'the order') for supply of ______(here in after called 'the Equipment /Item)to us Messrs ______(hereinafter called 'the order')

(hereinafter called 'the supplier') on submission of a Performance Bond to the satisfaction of NIT Jalandhar for the due performance of the said order.

We, Messer's	hereby submit the FDR/TDR No.	
issued by	(Name of Bank) for	pledged in
favour of Registrar, NIT Jalandhar as	performance guarantee amount and hereby	irrevocably,
	against any loss or damage caused or suffer pplier to perform or omission or negligence to perfor alandhar in terms of the order.	

We, the supplier, do hereby authorize Registrar, NIT Jalandhar to forfeit this Performance Guarantee amount / undertake to pay the amount due and payable under this guarantee without any demur merely on a demand from the NIT Jalandhar stating that the amount claimed is due by way of loss or damage caused to or would be caused to or suffered by the NIT Jalandhar by reason of any breach by us of any of the terms and conditions contained in the said order or by reason of our failure or omission or negligence to perform the said order or any part thereof. We, the Supplier, undertake to pay to NIT Jalandhar any amount so demanded by NIT Jalandhar, notwithstanding:

a) Any dispute or difference between NIT Jalandhar and supplier or any other person or between the supplier or any person or any suit or proceeding pending before any court or tribunal or arbitrator relating thereto; or

b) The invalidity, irregularity or unenforceability of the order; or

c) Any other circumstances which might otherwise constitute discharge of this guarantee, including any act of omission or commission on the part of NIT Jalandhar to enforce the obligations by the supplier or any other person for any reason whatsoever.

We, the Supplier, further agree that the performance Bond/ Guarantee herein contained shall be continued one and remain in full force and effect during the period that would be taken for the performance of the said order and that it shall continue to be enforceable till all the dues of the NIT Jalandhar under or by virtue of the said order have been fully paid and its claims satisfied or discharged or till the office of the Registrar, NIT Jalandhar certifies that terms and conditions of the said order have been fully and promptly carried out by us and accordingly discharges this Performance Bond/ Guarantee.

We, the Supplier, further agree with NIT Jalandhar, that NIT Jalandhar shall have the fullest liberty without our consent and without affecting in any manner our obligations hereunder to vary any of the terms and conditions of the said order or to extend time of performance by the said supplier from time to time or to postpone for any time or from time to time and of the powers exercisable by the NIT Jalandhar against the said supplier and forbear or enforce any of the terms and conditions relating to the order and we shall not be relieved from our liability by reason of any such variation or extension being granted to us or for any forbearance, act or omission on the part of NIT Jalandhar or any indulgence by NIT Jalandhar to us or by any such matter or thing whatsoever which under the law relating to sureties would, but for this provision, have effect of so relieving us.

This Performance Bond/Guarantee will not be discharged due to the change in the constitution of the supplier. We, the Supplier, undertake not to revoke this Performance Bond / Guarantee except with the prior consent of NIT Jalandhar in writing.

The disputes relating to this Bank Performance Bond / Guarantee shall be resolved as per the terms and conditions of the order.



G T Road By Pass, Jalandhar-144011, Punjab (India) EPABX-0181-2690301 & 453 website: <u>www.nitj.ac.in</u> email: <u>registrar@nitj.ac.in</u>

Annexure: "C"

FORMAT FOR PERFORMANCE BOND (BANK GUARANTEE)

(hereinafter called 'the Equipment /Item) to Messrs *(hereinafter called 'the supplier')* on submission of a Bank Guarantee to the satisfaction of NIT Jalandhar for the due performance of the said order.

We, _______(hereinafter called 'the Bank') at the request of the supplier do, as a primary obliger and not merely as surety, hereby irrevocably, unconditionally and absolutely undertake against any loss or damage caused or suffered by NIT Jalandhar by reason of any failure of the supplier to perform or omission or negligence to perform any part of its obligations to the satisfaction of NIT Jalandhar in terms of the order.

We, the Bank do hereby undertake to pay the amount due and payable under this guarantee without any demur merely on a demand from NIT Jalandhar stating that the amount claimed is due by way of loss or damage caused to or would be caused to or suffered by NIT Jalandhar by reason of any breach by the said supplier of any of the terms and conditions contained in a said order or any part thereof. Any such demand made on the Bank shall be conclusive as regards the amount due and payable by the bank under this guarantee, which shall not be considered as satisfied by any intermediate payment or satisfaction of any part of or obligation hereunder. However, our liability under this guarantee shall be restricted to an amount not exceeding_____.

We, the Bank, undertake to pay to NIT Jalandhar any amount so demanded by NIT Jalandhar, notwithstanding a). Any dispute and difference between NIT Jalandhar and supplier or any other person or between the supplier or any person or any suit or proceeding pending before any court or tribunal or arbitrator relating thereto or

a). The invalidity, irregularity or unenforceability of the order or

b). Any other circumstances which might otherwise constitute discharge of this guarantee, including any act of omission or commission on the part of NIT Jalandhar to enforce the obligations by the supplier or any other person for any reason whatsoever.

We, the Bank, further agree that the guarantee herein contained shall continue and remain in full force and effect during the period that would be taken for the performance of the said order and that it shall continue to be enforceable till all the dues of NIT Jalandhar under or by virtue of the said order have been fully paid and its claims satisfied or discharged or till the office of the Registrar, NIT Jalandhar confirms that the terms and conditions of the said order have been fully and promptly carried out by the said supplier and accordingly discharge this guarantee.

We, the Bank, hereby agree and undertake that any claim which the bank may have against the supplier shall be subject to and subordinate to the prior payment and performance in full of all the obligations of the bank hereunder and the bank will not, without prior written consent of NIT Jalandhar, exercise any legal rights or remedies of any kind in respect of any such payment or performance so long as the obligations of the bank hereunder remain owning and outstanding, regardless of the insolvency, liquidation or bankruptcy of the supplier or otherwise. We, the Bank, will not counter claim or set off against its liabilities to NIT Jalandhar hereunder any sum outstanding to the credit of NIT Jalandhar with it.

We, the Bank, further agree with NIT Jalandhar , that NIT Jalandhar shall have the fullest liberty without our consent and without affecting in any manner our obligations hereunder to vary any of the terms and conditions of the said order or to extend time of performance by the said supplier from time to time or to postpone for any time or from time to time and of the powers exercisable by the NIT Jalandhar against the said supplier and forbear or enforce any of the terms and conditions relating to the order and we shall not be relieved from our liability by reason of any such variation or extension being granted to the said supplier or for any forbearance, act or omission on the part of NIT Jalandhar or any indulgence by NIT Jalandhar to the said supplier or by any such matter or thing whatsoever which under the law relating to sureties would, but for this provision, have effect of so relieving us.

This guarantee will not be discharged due to the change in constitution of the Bank or the supplier.

We, the Bank, lastly undertake not to revoke this Guarantee during its currency except with the prior consent of NIT Jalandhar in writing.

The disputes relating to this Bank Guarantee shall be resolved as per the terms and conditions of the order.



G T Road By Pass, Jalandhar-144011, Punjab (India) EPABX-0181-2690301 & 453 website: <u>www.nitj.ac.in</u> email: <u>registrar@nitj.ac.in</u>

Annexure "D"

FORMAT FOR MANUFACTURER'S AUTHORIZATION FORM

To, The Registrar Dr B. R Ambedkar National Institute of Technology Jalandhar

Sub. : e-Tender for "_____".

Dear Sir,

We,	,	who	are	established	and	reputed manufacturers	of
	, ha	ving fa	actory/of	fice at		, hereby authorize	M/s
	[nar	ne & ado	dress of	agents/distribute	ors] to bid	I, negotiate and conclude the	order
with you for the above goo	ds n	nanufact	ured by	us.			

this business against this specific tender as for all business in the entire territory of India.

We hereby extend our full guarantee and warranty as per the terms and conditions of tender for the goods offered for supply against this invitation for bid by the above supplier.

*specify in detail manufacturer's responsibilities the services to be rendered by

M/s_____are as under:

i) _____

ii) _____

[Specify the services to be rendered by the agent/distributor] In case duties of the agent/distributor are changed or agent/ distributor is changed it shall be obligatory on us to automatically transfer all the duties and obligations to the new Indian Agent failing which we will ipso-facto become liable for all acts of commission or omission on the part of new Indian Agent/ distributor.

Yours faithfully,

[Name & Signature] For and on behalf of M/s. [Name of manufacturer]



G T Road By Pass, Jalandhar-144011, Punjab (India) EPABX-0181-2690301 & 453 website: <u>www.nitj.ac.in</u> email: <u>registrar@nitj.ac.in</u>

Annexure "E"

DECLARATION REGARDING BLACKLISTING / DEBARRING FOR TAKING PART IN TENDER Self Attested

I / We _____(Tenderer) hereby declare that the firm / agency namely M/s. ______has not been blacklisted or debarred in the past by Union / State Government or organization from taking part in Government tenders in India.

Or

I / We	_(Tenderer) hereby declare that the Firm /	agency nam	nely
M/s	was	blacklisted	or
debarred by Union / State Governme	ent or any Organization from taking part in G	overnment	
tenders for a period of			

years w.e.f	to	The period is over on
and now the firm/con	mpany is entitled to take	e part in Government tenders.

In case the above information found false I / we are fully aware that the tender/ contract will be rejected / cancelled by Director, NIT Jalandhar, and EMD / SD shall be forfeited.

DEPONENT Attested: (Stamp of Company with authorized sign) Name_____ Address _____



G T Road By Pass, Jalandhar-144011, Punjab (India) EPABX-0181-2690301 & 453 website: <u>www.nitj.ac.in</u> email: <u>registrar@nitj.ac.in</u>

Annexure: "F"

CERTIFICATE OF WARRANTY

- i) .I/We certify that the warranty shall be for a period of _____years for ______and starting from the date of satisfactory installation, commissioning and handing over of the Equipment /Item and of the works conducted therewith covered under the supply order in working order. During the warranty period, I/we shall provide free "after sale service" and the replacement of any part(s) of the Equipment /Item or rectification of defects of work of the Equipment /Item will be free of cost. The replacement of the parts shall be arranged by us, at our own cost and responsibility. We undertake that the above warranty shall begin only from the date of satisfactory and faultless functioning of the Equipment /Item for 60 days at NIT Jalandhar premises. The benefit of change in dates of the warranty period shall be in the interest of the use/your organization.
- ii). During the warranty period, we shall provide at least _____ preventive maintenance visits.
- iii).Uptime Guarantee: During the warranty period, we will be responsible to maintain the Equipment /Item in good working conditions for a period 350 days (i.e. 95% uptime) in a block of 365 days.
 - a). All complaints will be attended by us within 2 working days of receipt of the complaint in our office.
 - b). In case there is delay of more than 2 days in attending to a complaint from our side then you can count the number of days in excess of the permissible response time in the downtime. The above said response time of 2 days for attending to a complaint by us will not be counted in the downtime.
 - c). **Penalty**: We shall pay a penalty equivalent to **0.5 % of the FOB/CIF** value of the Equipment /Item for every week or part thereof delay in rectifying the defect.

Note: The right to accept the reason (s) for delay and consider reduction or wave off the penalty for the same shall be at the sole discretion of Director, NIT Jalandhar

iv). We certify that the Equipment /Item being/ quoted is the latest model and that spares for the Equipment /Item will be available for a period of at least_____years and we also guarantee that we will keep the organization informed of any update of the Equipment /Item over a period of ____ years.

- v). We guarantee that in case we fail to carry out the maintenance within the stipulated period, NIT Jalandhar reserves the right to get the maintenance work carried out at our risk, cost and responsibility after informing us. All the expenses including excess payment for repairs/maintenance shall be adjusted against the Performance Bank Guarantee. In case the expenses exceed the amount of Performance Bank Guarantee, the same shall be recoverable from us with/without interest in accordance with the circumstances.
- vi).We shall try to repair the Equipment /Item at NIT Jalandhar premises itself. However, the Equipment /Item will be taken to our site on our own expenses in case it is not possible to repair the same at NIT Jalandhar. We shall take the entire responsibility for the safe custody and transportation of the Equipment /Item taken out for repairs till the Equipment /Item is rehabilitated to the NIT Jalandhar after repair Any loss of Equipment /Item or its accessories under its charge on account of theft, fire or any other reasons shall be at our sole risk and responsibility which will be compensated to NIT Jalandhar for such losses at the FOB/CIF value for the damaged/lost Equipment /Item part, including accessories.
- vii. We undertake to perform calibration after every major repair/breakdown/taking the Equipment /Item for repair out of NIT Jalandhar premises.
- viii. In case of extended warrantee, we undertake to carry out annual calibration of the Equipment /Item.
- ix. We guarantee that we will supply spare parts if and when required on agreed basis for an agreed price. The agreed basis could be an agreed discount on the published catalogue price.
- x. We guarantee to the effect that before going out of production of spare parts, we will give adequate advance notice to you so that you may undertake to procure the balance of the life time requirements of spare parts.
- xi. We guarantee the entire unit against defects of manufacture, workmanship and poor quality of components.





G T Road By Pass, Jalandhar-144011, Punjab (India) EPABX-0181-2690301 & 453 website: <u>www.nitj.ac.in</u> email: <u>registrar@nitj.ac.in</u>

Annexure: "G"

SELF DECLARATION [For Local Content of Products, Services or Works]

To,

The Director Dr.B.R.Ambedkar NIT Jalandhar

- 1. With reference to Order No. P- 45021/2/2017-PP(BE-II) dated 16-09-2020 of DPIIT, Ministry of Commerce and Industry, Govt. of India, we fall under the following category of supplier (please tick the correct category) for the items for which this tender has been floated and being bided.
 - Class I local supplier has local content equal to more than 50%. Local contents added at

_____(name of location).

- Class II local supplier has local content more than 20% but less than 50%. Local contents added at (name of location).
- Non-local supplier has local content less than or equal to 20%. Local contents added at _____(name of location).
- 2. We are solely responsible for the abovementioned declaration in respect of category of supplier. False declarations will be in breach of the Code of Integrity under Rule 175(1)(i)(h) of the General Financial Rules for which we may can be debarred for up to 2 years as per Rule 151(iii) of the General Financial Rules along with such other actions as may be permissible under law.

Signature & seal of the company

Name and address of the organization

.....

Note: In cases of procurement for a value in excess of Rs. 10 crores, the 'Class-I local supplier' / 'Class-II local supplier' shall be required to provide a certificate from the statutory auditor or cost auditor of the company (in the case of companies) or from a practicing cost accountant or practicing chartered accountant (in respect of suppliers other than companies) giving the percentage of local content.