



**Dr B R AMBEDKAR NATIONAL INSTITUTE OF TECHNOLOGY
G T Road By Pass, Jalandhar-144011, Punjab (India)**

CORRIGENDUM

In pursuant to queries from some bidders about specifications for e-tender ref no. NITJ/Pur/ EO/ 76/19 e tender no. 45/2019 (Testing and commissioning of AIR conditioning VRF units in Lecture Halls of extended work shop and conference hall) , the revised technical specifications of VRF AC unit with one Centralized Remote Control are given as under:

Technical Specification of VRF AC Unit with Centralized Remote Control

Cooling Capacity	= 1562900 Btu/hr
Outdoor Unit Capacity	= 20 HP, 16 Ton
Indoor Unit Type	= Cassette Type
Indoor Unit Capacity	= 305 Ton (04 Nos.)
Input	= 12100 Watt
Current	= 19.77 Amp
Heating Capacity	= 152900 Btu/hr
Input	= 11800 Watt
Current	= 19.28 Amp
Phase	= 3 Nos.
Voltage	= 380-415 Volt
Frequency	= 50Hz
Refrigerant	= R410 A
Max H.E. Pressure	= 5000 KPa


A.E. (E)

However, there is no change in tender, terms and conditions.